

Standard Series: 3-5 Year Life

Model No.	Standby Time – Minutes						Standby Time - Hours					
	3	5	10	15	20	30	1	3	5	10	20	24
LC-R064R2P	90	82	55	47	40	31	18	7.7	4.9	2.5	1.2	1
LC-R067R2P	148	125	93	74	62	47	30	11	7.5	4	2.1	1.8
LC-R0612P1	250	211	157	124	103	77	46	20	12	6.2	3.3	2.7
LC-R121R3P	44	38	28	24	21	16	10	4.2	2.6	1.5	0.8	*
LC-R122R2P	74	65	51	42	36	28	19	7	4.6	2.4	1.2	*
LC-R123R4P	110	100	79	66	56	43	24	9.8	6.3	3.5	1.9	*
LC-R127R2P	296	250	186	148	124	94	61	23	15	8	4.2	3.6
LC-R127R2P1	296	250	186	148	124	94	61	23	15	8	4.2	3.6
LC-RA1212P1	590	413	308	245	207	155	101	39	24	12	6.8	5.7
LC-R1233P	1413	1188	866	688	427	459	265	104	67	37	19	*

High Power UPS Series: 3-5 Year Life

Model No.	Standby Time – Minutes						Standby Time - Hours					
	3	5	10	15	20	30	1	3	5	10	20	24
UP-RW1220P1	177	137	102	82	66	47	*	*	*	*	*	*
UP-RWA1232P1	294	230	164	130	110	86	*	*	*	*	*	*
UP-RW1245P1	434	330	234	180	146	109	*	*	*	*	*	*

Trickle Long Life Series: 6-10 Year Life

Model No.	Standby Time – Minutes						Standby Time - Hours					
	3	5	10	15	20	30	1	3	5	10	20	24
LC-X1220AP	755	657	480	388	333	207	125	59	35	18	9.4	8.9
LC-X1228AP	1200	1000	770	600	490	370	210	80	48	26	12	11
LC-X1242AP	1590	1400	1030	790	660	500	325	130	87	43	22	19
LC-X1265P	1690	1630	1250	993	879	689	461	172	108	62	33	27
LC-XA12100P	2600	2400	2050	1730	1500	1100	690	264	152	83	45	37

National Batteries Limited

PO Box 44-202, Point Chevalier, Auckland, New Zealand

Phone: +64 9 302 1265 Fax: +64 9 302 1278 Web: <http://www.natbat.co.nz>

Standard Series: 3-5 Year Life

Model No.	Standby Time – Minutes						Standby Time - Hours					
	3	5	10	15	20	30	1	3	5	10	20	24
LC-R064R2P	100	85	59	48	41	31	18	7.8	5	2.5	1.2	1
LC-R067R2P	165	135	97	76	64	48	31	12	7.5	4	2.1	1.8
LC-R0612P1	279	229	165	129	106	79	47	20	12	6.4	3.4	2.8
LC-R121R3P	51	43	31	26	22	17	10	4.3	2.7	1.5	0.8	*
LC-R122R2P	85	72	55	45	37	28	17	7.2	4.6	2.5	1.3	*
LC-R123R4P	125	115	86	70	58	44	25	9.9	6.4	3.6	2	*
LC-R127R2P	330	270	194	152	127	95	61	23	15	8.1	4.2	3.6
LC-R127R2P1	330	270	194	152	127	95	61	23	15	8.1	4.2	3.6
LC-RA1212P1	597	447	323	252	211	157	102	40	24	12	6.9	5.8
LC-R1233P	1561	1269	905	767	519	454	272	106	68	37	19	*

High Power UPS Series: 3-5 Year Life

Model No.	Standby Time – Minutes						Standby Time - Hours					
	3	5	10	15	20	30	1	3	5	10	20	24
UP-RW1220P1	197	152	107	84	69	49	*	*	*	*	*	*
UP-RWA1232P1	327	255	173	136	115	89	*	*	*	*	*	*
UP-RW1245P1	462	360	246	186	151	110	*	*	*	*	*	*

Trickle Long Life Series: 6-10 Year Life

Model No.	Standby Time – Minutes						Standby Time - Hours					
	3	5	10	15	20	30	1	3	5	10	20	24
LC-X1220AP	818	705	495	399	345	222	131	60	35	18	9.5	8.9
LC-X1228AP	1300	1075	795	622	517	397	215	81	49	26	12	11
LC-X1242AP	1700	1425	1035	810	685	527	337	133	88	43	22	19
LC-X1265P	1870	1745	1310	1031	895	702	471	174	109	62	33	27
LC-XA12100P	2750	2480	2125	1765	1520	1150	705	266	153	83	45	37

National Batteries Limited

PO Box 44-202, Point Chevalier, Auckland, New Zealand

Phone: +64 9 302 1265 Fax: +64 9 302 1278 Web: <http://www.natbat.co.nz>

Standard Series: 3-5 Year Life

Model No.	Standby Time – Minutes						Standby Time - Hours					
	3	5	10	15	20	30	1	3	5	10	20	24
LC-R064R2P	110	87	62	48	41	31	18	7.8	5.1	2.5	1.2	1
LC-R067R2P	182	145	101	78	65	48	31	12	7.5	4	2.1	1.8
LC-R0612P1	308	246	172	133	108	80	48	20	12	6.5	3.4	2.8
LC-R121R3P	58	48	34	27	23	17	10	4.3	2.7	1.4	0.8	*
LC-R122R2P	93	77	57	46	38	29	17	7.4	4.8	2.6	1.3	*
LC-R123R4P	140	130	93	73	60	45	25	10	6.5	3.6	2	*
LC-R127R2P	364	291	203	156	130	96	62	24	15	8.1	4.2	3.6
LC-R127R2P1	364	291	203	156	130	96	62	24	15	8.1	4.2	3.6
LC-RA1212P1	605	482	338	260	216	160	104	41	25	13	7	5.8
LC-R1233P	1710	1350	945	847	612	450	280	108	69	37	19	*

High Power UPS Series: 3-5 Year Life

Model No.	Standby Time – Minutes						Standby Time - Hours					
	3	5	10	15	20	30	1	3	5	10	20	24
UP-RW1220P1	217	167	113	87	73	52	*	*	*	*	*	*
UP-RWA1232P1	361	281	182	142	120	93	*	*	*	*	*	*
UP-RW1245P1	490	390	258	193	156	111	*	*	*	*	*	*

Trickle Long Life Series: 6-10 Year Life

Model No.	Standby Time – Minutes						Standby Time - Hours					
	3	5	10	15	20	30	1	3	5	10	20	24
LC-X1220AP	881	752	510	410	356	236	136	59	35	18	9.5	8.9
LC-X1228AP	1400	1150	820	645	545	425	220	82	50	27	13	11
LC-X1242AP	1810	1450	1040	830	710	555	350	136	89	44	23	19
LC-X1265P	2050	1860	1370	1070	912	716	480	177	111	63	33	27
LC-XA12100P	2900	2560	2200	1800	1540	1200	720	268	154	84	45	37

National Batteries Limited

PO Box 44-202, Point Chevalier, Auckland, New Zealand

Phone: +64 9 302 1265 Fax: +64 9 302 1278 Web: <http://www.natbat.co.nz>

Standard Series: 3-5 Year Life

Model No.	Standby Time – Minutes						Standby Time - Hours					
	3	5	10	15	20	30	1	3	5	10	20	24
LC-R064R2P	115	91	64	49	42	32	18	7.8	5.1	2.5	1.2	1
LC-R067R2P	193	152	104	79	66	49	31	12	7.6	4.1	2.1	1.8
LC-R0612P1	326	255	176	135	109	81	50	20	12	6.5	3.4	2.8
LC-R121R3P	60	50	36	29	24	17	11	4.4	2.7	1.4	0.8	*
LC-R122R2P	97	83	60	47	40	30	18	7.6	4.9	2.7	1.4	*
LC-R123R4P	150	130	97	75	61	47	27	10	6.5	3.6	2	*
LC-R127R2P	386	303	208	159	131	98	62	24	15	8.2	4.2	3.6
LC-R127R2P1	386	303	208	159	131	98	62	24	15	8.2	4.2	3.6
LC-RA1212P1	612	496	344	265	218	161	104	41	25	13	7	5.8
LC-R1233P	1790	1395	967	806	621	459	282	109	69	37	19	*

High Power UPS Series: 3-5 Year Life

Model No.	Standby Time – Minutes						Standby Time - Hours					
	3	5	10	15	20	30	1	3	5	10	20	24
UP-RW1220P1	227	173	116	89	74	54	*	*	*	*	*	*
UP-RWA1232P1	385	295	187	149	124	95	*	*	*	*	*	*
UP-RW1245P1	510	400	263	194	157	111	*	*	*	*	*	*

Trickle Long Life Series: 6-10 Year Life

Model No.	Standby Time – Minutes						Standby Time - Hours					
	3	5	10	15	20	30	1	3	5	10	20	24
LC-X1220AP	925	779	519	415	361	245	137	62	38	19	9.4	8.9
LC-X1228AP	1475	1225	835	647	547	427	260	83	50	27	13	11
LC-X1242AP	1880	1550	1095	890	750	577	375	139	90	44	23	19
LC-X1265P	2175	1930	1410	1085	926	723	487	183	115	63	33	27
LC-XA12100P	3000	2655	2250	1850	1595	1225	740	272	159	84	45	37

National Batteries Limited

PO Box 44-202, Point Chevalier, Auckland, New Zealand

Phone: +64 9 302 1265 Fax: +64 9 302 1278 Web: <http://www.natbat.co.nz>

Standard Series: 3-5 Year Life

Model No.	Standby Time – Minutes						Standby Time - Hours					
	3	5	10	15	20	30	1	3	5	10	20	24
LC-R064R2P	120	95	65	50	42	33	18	7.8	5.1	2.5	1.2	1
LC-R067R2P	204	158	106	80	66	50	30	12	7.6	4.1	2.1	1.8
LC-R0612P1	344	263	179	137	110	82	51	20	12	6.5	3.4	2.8
LC-R121R3P	62	52	38	30	24	17	11	4.4	2.7	1.4	0.8	*
LC-R122R2P	100	89	63	48	41	30	19	7.7	4.9	2.7	1.4	*
LC-R123R4P	160	130	100	76	62	48	28	10	6.5	3.6	2	*
LC-R127R2P	408	316	213	162	133	100	62	24	15	8.2	4.2	3.6
LC-R127R2P1	408	316	213	162	133	100	62	24	15	8.2	4.2	3.6
LC-RA1212P1	620	510	350	270	220	162	104	42	25	13	7	5.8
LC-R1233P	1870	1440	990	765	630	468	284	110	70	37	19	*

High Power UPS Series: 3-5 Year Life

Model No.	Standby Time – Minutes						Standby Time - Hours					
	3	5	10	15	20	30	1	3	5	10	20	24
UP-RW1220P1	237	180	120	91	75	57	*	*	*	*	*	*
UP-RWA1232P1	410	310	192	157	128	97	*	*	*	*	*	*
UP-RW1245P1	530	410	268	195	159	112	*	*	*	*	*	*

Trickle Long Life Series: 6-10 Year Life

Model No.	Standby Time – Minutes						Standby Time - Hours					
	3	5	10	15	20	30	1	3	5	10	20	24
LC-X1220AP	968	805	527	418	366	254	137	64	39	19	9.3	8.9
LC-X1228AP	1550	1300	850	650	550	430	300	84	51	27	13	11
LC-X1242AP	1950	1650	1150	950	790	600	400	143	92	45	23	19
LC-X1265P	2300	2000	1450	1100	940	730	494	189	119	64	34	28
LC-XA12100P	3100	2750	2300	1900	1650	1250	760	276	164	85	45	37

National Batteries Limited

PO Box 44-202, Point Chevalier, Auckland, New Zealand

Phone: +64 9 302 1265 Fax: +64 9 302 1278 Web: <http://www.natbat.co.nz>